

Discontinued S-Series Furnace Ratings



Due to an internal system error, a number of Trane system ratings were mistakenly published using the downflow versions of S9V2 and S9X2 furnaces in horizontal applications. Downflow models of the S-series furnaces cannot be installed in a horizontal position, and these ratings should not have been published. These ratings have all been discontinued in AHRI effective immediately, and these systems should not be installed.

For horizontal application, please utilize the upflow/horizontal models of the S-series furnaces.

Please ensure that your customers are aware of these discontinued ratings. We apologize for any inconvenience.

More information on the ratings can be found <u>here</u>.

For more information or questions, please contact:

Jim Lowell, Product Manager, Air Conditioners 903-730-4506 | Jim.Lowell@irco.com

Tim Storm, Product Manager, Heat Pumps 903-730-4505 | <u>Tim.Storm@irco.com</u>

Patrick Van Deventer, Product Manager, Coils 903-730-4521 | Patrick.VanDeventer@irco.com

Mark Woodruff, Product Manager, Furnaces 903-730-4561 | Mark.Woodruff@irco.com

